



## INSPECTION CERTIFICATE

In accordance to EN ISO 10204 – 2004 , type 3.1

### 1. Name and address of manufacturer:

HERZ Kovinsko predelovalno podjetje d.d., Grmaška cesta 3, 1275 Šmartno pri Litiji  
Tel.: +386 01 8962-100, Fax.:+386 01 8962-140, <http://www.herz.si> , [info@herz.si](mailto:info@herz.si)

### 2. Identification of the product type and catalog number for product identification:

KV000 OZ, KV001 OZ, KV002 OZ, KV003 OZ, KV004 OZ, KV005 OZ, KV006 OZ, KV007 OZ

### 3. Size of product: 1/4", 3/8", 1/2", 3/4", 1", 5/4", 6/4", 2"

### 4. Name of customer: OZ Slovakia, s.r.o., Vinična 5, Dudince

### 5. Intended use: Use for oxygen installations.

### 6. The Certification Body Quality Superintending Company Ltd , 10000 Zagreb, Ljudevita Gaja 17/III,Zagreb , Croatia certified that the product characteristics are in conformity to the requirements of the following regulations and standards

-technical documentation of producer

-HRN EN 331:2000 Manually operated ball valves and closed bottom taper plug valves for gas installations for buildings **Number of issued certificate:** N 43488/5, Valid until: 17.07.2019

### 7. Defined properties

TEHNICAL SPECIFICATION			
Construction parts	Material	Mark	Standard
body	Pressed brass	CuZn39Pb2	EN 12420
ball	MS 58	CuZn39Pb3	EN 12165
ball seals	O-ring	PTFE	
spindle seals	O-ring	NBR	DIN 3771
handle	stell plate	S275JR	EN 10025
MS 58			

Nominal pressure: ....from 0 to 30 bar

Work temperature: ....from –20°C to + 150°C

Test medium: .....air

Test pressure: .....45 bar (1,5xPN)

Valves are cleaned and degreased.

### 8. Characteristics of the products listed above are in accordance with the above properties. sole responsibility of the manufacturer, cited above.

Šmartno pri Litiji, 12.04.2016



Manager of quality department:

Valentin Kodrič