



CERTIFICATE OF COMPLIANCE WITH THE ORDER 2.1

According to EN 10204

HERZ Calis 3-way valves **17761XX** are made of cast brass, nickel-plated with outside thread, according to ISO 228/1, flat seal without union nut. Pipe connections are not included. Spindle made of Niro steel with soft seal valve cone for regulating.

MATERIAL:

Brass of valve body	EN 1982 – CC754S-GM
Brass of turning parts	EN 12164 – CW614 N-M-S
O-rings spindle	EP 851
O-ring seat	EPDM 80Sh
O-ring outside	70 EPDM 281
Flat seal seat	85 EPDM 282 85+5ShA
Pressure-pin	1.4301
Springs	X12CrNi17 7
Lock washer	Niro X7CrNiAl177 DIN6799

SIZES:

Dimensions and connection thread according to standard sheet for 7761

FUNCTION:

Each delivered part is tested to impermeability and the parts are permanently embossed with the test mark.

The maximum operating pressure is 16 bar

The minimum operat

The maximum operating temperature is 130 °C.

Water quality according to Austrian standard ÖNORM H 5195 and/or VDI specification 2035.

Vienna, 08.10.2013

HERZ Armaturen Ges.m.b.H



Ing. Wolfgang Rauch
QualityManager

CERTIFIKÁT ZHODY S NARIADENÍM 2.1.

Podľa EN 10204

HERZ 3 cestný ventil **17761XX** teleso ventilu z mosadze, podľa ISO 228/1, ploché tesnenie bez prevlečnej matice. Pripojenie potrubia nie je súčasť dodávky. Vreteno z nerezovej ocele, tesnenia EPDM.

Materiál:

Materiál telesa ventilu:	EN 1982 – CC754S-GM
Materiál pohyblivých častí:	EN 12164 – CW614 N-M-S
O-krúžok - vreteno:	EP 851
O-krúžok - sedlo:	EPDM 80Sh
Vonkajší O-krúžok:	70 EPDM 281
Plocho tesniace sedlo:	85 EPDM 282 85+5ShA
Prítlačný kolík:	1.4301
Pružiny:	X12CrNi17 7
Pružná podložka:	Niro X7CrNiAl177 DIN6799

Rozmery, dimenzie:

Rozmery, dimenzie, vyhotovenie v zmysle technického listu pre 7761

Prevádzkové parametre:

Každá dodávaná armatúra je tlakovo testovaná a trvalo označená značkou testovania.

Maximálna prevádzkový tlak je 16 bar.

Minimálna prevádzková teplota je 2°C.

Maximálna prevádzková teplota je 130°C.

Kvalita vody podľa rakúskych štandardov ÖNORM H 5195 and/or VDI specification 2035.

Vienna, 08.10.2013

HERZ Armaturen Ges.m.b.H



Ing. Wolfgang Rauch
QualityManager